CORRIGENDUM - 1

K-RIDE

`

SL. NO.	SECTION	EXISTING CONDITION	AMENDED AS
1	**Section-8 Terms of Reference (under Relevant Para)**	**6.7.26 Sheds and Buildings** The DDC shall design solar panels on the top of all sheds, buildings etc., wherever it is feasible to provide solar panels for generation of electricity. The DDC shall also design all the associated components for generation of electricity and for using the same in the depots.	**6.7.26 Sheds and Buildings** DDC shall design Buildings/sheds in depot so that solar panels can be installed by agency (to be finalised under RESCO model). DDC will also design "Integration of electricity generated from solar panel with BESCOM supply in depot"

K-RIDE