REPLY TO PRE-BID QUERIES

S. N	Clause Reference	Relevant Quote	Query/ Comment/ Suggestion	Employer's Response
1		**General**	We request the Employer to kindly restrict the design scope of works for stations for Civil and Structural works including Steel FOB, roof structure, and PEB works for stations with all associated works (Excluding Architectural Finishes and E&M works) only, as which are to be only executed by Contractor for this package. OR We request the Employer to include the Scope of execution of Architectural and MEP works also in this package Contractor scope in addition to the design scope mentioned in the tender, as the same is generally followed in the industry. (i.e. Civil, Structural, Architectural, MEP, and other works on Design and Construction basis as one package)	Tender condition prevails.

K-RIDE

S. N	Clause Reference	Relevant Quote	Query/ Comment/ Suggestion	Employer's Response
2	DBR Clause 2.4.4 Pg. no. 11	**2.4.4. Earthquake Loads (EQ)** **Horizontal Seismic Coefficient** **Ah = (Z/2) * (I/R) * (Sa/g)** **Where,** **Z = peak ground acceleration or zone factor = 0.24**	Z = Peak ground acceleration or zone factor = 0.24 is mentioned, which is applicable for Seismic Zone IV. Whereas the proposed project location is Bangalore and which falls under Seismic Zone II.	Bengaluru comes under Zone II and the seismic requirements as per IS 1893 (Part-1) for Zone II may be referred
3		**General**	As requested earlier once again we sincerely request you to kindly extend the due date of submission of the tender till 30.09.2023, please	SN 4 of Corrigendum 2 holds good