

Query No.	Reference to Tender Doc.	Description of Clause (Existing provision)	Queries	Reply/Remarks
1	Price schedule, Sl. No.13,14, 15, 16,17,18,19,20 on KTPP portal	1.1 kV XLPE or Heat resistant PVC insulated, PVC extruded inner sheath armoured LT UG cable as per IS:1554 part-1 or IS:7098, part-1, armouring stripe thickness and resistivity as per IS:3975.	For 1.1 KV LT UG cables please confirm the requirement of cable is XLPE or heat resistant PVC insulated cable and please confirm the conductor of material.	Cable requirement is XLPE and for the conductor material please refer Section-5, technical specification of cables of Tender document.
2	Price schedule Sl. No.10,11 & 12 on KTPP portal	11 kV XLPE or Heat resistant PVC insulated, PVC extruded inner sheath armoured LT UG cable as per IS:1554 part-1 or IS:7098, part-1, armouring strip thickness and resistivity as per IS:3975.	For 1.1 KV LT UG cables please confirm the requirement of cable is XLPE or heat resistant PVC insulated cable and please confirm the conductor of material.	Cable requirement is XLPE and for the conductor material please refer Section-4, technical specification of cables of tender document.
3	Price schedule Sl. No.13 on KTPP portal	1.1 kV XLPE or heat resistant PVC insulated, PVC extruded, inner sheath armoured LT UG cable as per IS:1554 (part-1) or IS:7098 (part-1) armouring strip and resistivity as IS:3975 10, sq mm, 2 core (9 GI strips:4*0.8mm)	For Sl. No.13 of BOQ, 2C*10 sq.mm ((strips, 4*0.08mm given) while as per IS fictitious diameter round wire armour applicable. Kindly confirm. And number of armour wire is such as to meet min.90%.	Description of item as mentioned in Price schedule of KTPP Portal shall prevail.
4	Price schedule Sl. No.14 on KTPP portal	1.1 kV XLPE or heat resistant PVC insulated, PVC extruded, inner sheath armoured LT UG cable as per IS:1554 (part-1) or IS:7098 (part-1) armouring strip and resistivity as IS:3975 16 sq. mm, 2 core (9 GI strips:4*0.8mm)	For Sl. No.14 of BOQ, 2C*16 sq.mm (strips, 4*0.08mm given) while as per IS fictitious diameter round wire armour applicable. Kindly confirm. And number of armour wire is such as to meet min.90%.	Description of item as mentioned in Price schedule of KTPP Portal shall prevail.
5	Price schedule Sl. No.2 & 3 on KTPP portal	Conventional RMU (VCB type) with copper bus bar, 350 MVA, 630 Amps as per IEC 62271/IS:3427	Please confirm whether the conventional RMU shall be DAS or Non-DAS RMUs.	Conventional RMU shall be non-DAS as per BESCO requirement.

6	Price schedule Sl. No.4,5,6 on KTPP portal	Sl.no 4,5,6: Compact RMU (VCB/SF6 type) with Cu bus bar, 350 MVA, 630A as per IEC:62271/IS:3427.	Please confirm Sl. No.4,5,6 shall be DAS RMUs or Non-DAS RMUs	For Sl. No.4,5,6 Compact RMUs shall be non-DAS as per BESCO requirement.
7	Price schedule Sl. No.2,3,4,5,6 on KTPP portal	<ol style="list-style-type: none"> 1. Conventional RMU (VCB type) with Cu busbar, 350 MVA, 630 A as per IEC:62271/IS-3427. 2. Compact RMU (VCB/SF6 type) with Cu busbar, 350 MVA, 630 A as per IEC:62271/IS-3427. 	Can we offer 11 kV, SF-6, 630A for both compact RMUs or non-DAS RMUs.	Conventional RMU along with VCB can be supplied and for Compact RMU along with SF-6 can be supplied. Refer Section-3 of technical specification of tender document.
8	Section-8B, Technical specification.	Specification of RMU.	Extensibility is required for manual RMUs as per tender details.	Specification of tender document shall prevail.
9	Section-8B Technical specification.	Specification of RMU	Metering is required for non-DAS RMUs as per BESCO non-DAS RMU specifications (as per tender details), Also, kindly let me know, non-DAS RMU required motorised/manual	Metering is required for non-DAS RMU. The RMU shall be of manual type.
10	Clause No.17 of Section-8A: Employer requirement. (Pg.249,250)	<p>17. RESPONSIBILITIES OF CONTRACTOR (Section 8A- Employers Requirement)</p> <p>“17.1 The Contractor shall liaison with ESCOM/ KPTCL/ PGCL, State/Central Government and local bodies till completion of works in all respect.....”</p>	Approval for Electrical Inspectorate for the work carried out will be comes under whose scope and approval from BBMP/KIADB/BDA/Railways or any other Govt. approval coming under whose scope.	Pl. refer clause No.17 of Section-8A: Employers requirement of tender document.

		17.2.5 Safe guarding the environment.		
11	Section-2: Instructions to Tenderers. Clause 13.7 (Pg-41)	The part of EMD amount is Rs.1 lakh accepted in the form of electronic cash (not through DD/BG) and will be maintained in the Govt. of Karnataka central pooling account held at ICICI Bank until the contract closed. The balance required EMD of Rs.13,41,039/- to be furnished in the form of Bank Guarantee (BG) of any Nationalized bank/Scheduled bank (as per RBI guidelines) payable to Managing Director/KRIDE, Bengaluru.	We hereby request client to accept the full amount of EMD i.e Rs.14,41,039/- in to BG format.	Tender condition shall prevail.
12	General	--	We request client to share all tender drawings (AutoCAD) files.	The work is shifting of utility and work will be executed as per site condition/requirement. Now at this juncture, drawings are not required.
13	Section-5, Conditions of Contract. Clause No.12 (Pg.111)	Contractor's Risk 12.1- All risks of loss of or damage to physical property and personal injury and death which arise during and in consequence of the performance of the contract other than expected risks are the responsibility of the contractor.	The contractor hedges these risks/losses by having valid CAR or equivalent policy with a defined upper limit of coverage. We request Client to define the upper limit so that all bidders will cost it at par. Eg.100% project estimated cost.	Please refer Section-6: Contract data of tender document.

14	Section-5: Conditions of contract and SCC. Clause No.13 (Pg.111)	Insurance. Min. Coverage of insurance.	We request client to define the upper limit so that all bidders will cost at par. Eg. 100% of the project estimated cost.	Please refer Section-6: Contract data of tender document.
15	Section-5: Conditions of Contract Clause 37.1 (Pg.117)	Payments shall be adjusted for deductions for advance payments other than recoveries in terms of contract and taxes, at source as applicable under law. The employer shall pay the contractor within 60 days of submission of bill. The contractor shall be liable to pay liquidated damages for short fall in progress.	We request client to revise the clause to within 30 days to improve the project cash flow.	Tender condition will prevail. However, KRIDE will make all efforts to make payment as early possible.
16	Section-6: Contract data (Pg.134)	"For the purpose of this clause, the contract value of the works shall be taken as value of work as per contract agreement including any supplementary work order/contract agreement issued. Provided also that the total amount liquidated damages under this condition shall not exceed 10% of the contract value or of the total value of the item or groups of item of work for which a separated distinct completion period is specified in the contract.	We request client to limit the maximum amount up to 5% of the final contract price or total invoiced till date, whichever is lesser.	Tender condition shall prevail.
17	Price schedule on KTPP Portal	No mention of cable specification.	We are assuming all the cables mentioned in the	Please refer technical specification of cables

			estimation are aluminium cables.	in tender document (Section-8B).
18	Section-09: Bill of quantities and payment terms. (Pg.472)	Approved list of materials.	Fabrication material made from approved brands mentioned in RFP will be submitted for in prior approval.	Agreed. Inspection and acceptance shall be done by BESCO.
19	Section-2 Instructions to tenderers. Clause No.11 (Pg.22)	Tender prices.	We will include co-ordination charges with other utility agencies like BWSSB etc. as required during the execution of the work.	Please refer clause No.17 of Section-8A: Employers requirement of tender document.
20	General	--	We request for an excel for the <ol style="list-style-type: none"> 1. The budget/estimated BOQ for our working. 2. Tender drawings in drawing format. 	<ol style="list-style-type: none"> 1. The BOQ can be downloaded from KTPP Portal. 2. Reply made at Sl. No.12 holds good.