BANASWADI SUBURBAN
DN LINE
UP LINE
NAGAWARA SUBURBAN
DN LINE
UP LINE
EXG. RD-1 LOOP LINE CSL - 821 m (FM TO FM)
EXG. RD-3 LOOP LINE CSL - 816 m (FM TO FM)
TO BE DISMANTLED FOR A LENGTH=20m
BSRP UP TRACK
Curve No. = 13 - RH
Curve CH:4453.585m
R = 1000m
Degree =1.750°
Delta = 4°06'57.14"
CCL = 31.835m
TRL = 40.00m
TTL = 71.835m
Ca = 60mm
Cd = 51.614mm
Cg = 1 in667m
Max. Speed = 90kmph
BSRP DOWN TRACK
Curve No. = 13 - RH
Curve CH:4468.167m
R = 1000m
Degree =1.750°
Delta = 4°06'57.14"
CCL = 31.836m
TRL = 40.00m
TTL = 71.835m
Ca = 60mm
Cd = 51.614mm
Cg = 1 in667m
Max. Speed = 90kmph
IOL FOR DN LINE CH: 4569.500
IOL FOR UP LINE CH: 4569.500
SSP BANASWADI CH: 4+650 KM
BSRP UP TRACK
Curve No. = 14 - LH
Curve CH:4639.324m
R = 750m
Degree =2.333°
Delta = 4°07'00.05"
CCL = 33.887m
TRL = 20.00m
TTL = 36.956m
Ca = 40mm
Cd = 37.625mm
Cg = 1 in500m
Max. Speed = 65kmph
BSRP DOWN TRACK
Curve No. = 14 - LH
Curve CH:4613.753m
R = 1000m
Degree =1.750°
Delta = 3°59'04.17"
CCL = 29.543m
TTL = 54.787m
Ca = 60mm
Cd = 51.614mm
Cg = 1 in667m
Max. Speed = 90kmph
LEVEL F 1 in 1071
F 1 in 1071 F 1 in 132
F 1 in 132 LEVEL
KM 5
ACC CENTRE FOR DN MAIN
ACC CENTRE FOR UP MAIN
TENTATIVE LOCATION OF DA SHOWN, ONE TO BE SUPPORTED FROM TRUSSES AND DISTANCE OF TRUSSES REQUIRED FROM STATION BUILDING CONTRACTOR.
CL OF KAVERI NAGAR (FUTURE STATION) (SUBURBAN AT GRADE PF's & ELEVATED STATION) AT CH: 5400 RAIL LEVEL: 903.957
PROPOSED SUBURBAN ISLAND PLATFORM
BSRP UP TRACK
Curve No. = 15A - LH
Curve CH:5537.565m
R = 875m
Degree =1.990°
Delta = 2°44'43.43"
BSRP DOWN TRACK
Curve No. = 15A - LH
Curve CH:5564.544m
R = 875m
Degree =2.000°
Delta = 2°44'43.43"
BSRP UP TRACK
Curve No. = 15B - RH
Curve CH:5622.654m
R = 870.5m
Degree =2.010°
Delta = 2°44'43.43"
BSRP DOWN TRACK
Curve No. = 15B - LH
Curve CH:5649.633m
R = 875m
Degree =2.000°
Delta = 2°44'43.43"
LEVEL F 1 in 118
UIOL FOR DN LINE CH: 5620.500
UIOL FOR UP LINE CH: 5620.500
KM 6
BSRP UP TRACK
Curve No. = 16 - LH
Curve CH:6130.199m
R = 964.5m
BSRP DOWN TRACK
Curve No. = 16 - LH
Curve CH:6155.319m
R = 960m
F 1 in 118 F 1 in 108
F 1 in 108 F 1 in 896
F 1 in 896 R 1 in 2101
R 1 in 2101 LEVEL
UIOL FOR UP LINE CH: 6462.000
UIOL FOR DN LINE CH: 6462.000
BSRP UP TRACK
Curve No. = 17 - LH
Curve CH:6810.457m
R = 493.1m
Degree = 3.549°
Delta = 41°09'07.75"
BSRP DOWN TRACK
Curve No. = 17 - LH
Curve CH:6831.951m
R = 488.6m
Degree = 3.582°
Delta = 41°09'07.75"
KM 7
Refer Drawing No.- KRDD001-TDR-CR02-GEN-OCS-PGP-00004
C.No.12
C.No.13
C.No.14
C.No.15
C.No.15A
C.No.15B
C.No.16
C.No.17
210/000
210/100
210/200
210/300
210/400
210/500
210/600
210/700
210/800
210/900
211/000
211/100
211/200
211/300
211/400
211/500
211/600
211/700
211/800
211/900
212/000
212/100
212/200
212/300
212/400
212/500
212/600
4+300
4+400
4+500
4+600
4+700
4+800
4+900
5+000
5+100
5+200
5+300
5+400
5+500
5+600
5+700
5+800
5+900
6+000
6+100
6+200
6+300
6+400
6+500
6+600
6+700
6+800
6+900
7+000


BENNIGANAHALL
SOLADEVANAHALLI
ACC DN MAIN
ACC UP MAIN
IOL
UIOL
KM5
KM6
KM7
KAVERI NAGAR (FUTURE) SUBURBAN
CH: 5+400Km
DN LINE
BANASWADI SUBURBAN
UP LINE
NAGAWARA SUBURBAN
SSP BANASWADI CH: 4+650 KM
1197.000
1199.500
1206.000
596.500
603.00
495.000
589.500
661.500
985.500
1251.000
CH: 4+569.500
CH: 5+094.000
CH: 5+620.500
CH: 6+043.500
CH: 6+462.000
CH: 6+979.500

## LEGEND

| Sr. No. | DESCRIPTION | SYMBOL |
|---|---|---|
| 1 | OHE Span length in metres | (30) |
| 2 | Insulated Overlap (IOL) | |
| 3 | Un insulated Overlap (UIOL) | |
| 4 | Section Insulator | |
| 5 | Single Pole Isolator | |
| 6 | Double pole Isolator with Earth Heel | |
| 7 | Normal Mast with Single Cantilever Assembly at Viaduct | |
| 8 | Normal Mast with Multiple Cantilever Assembly at Viaduct | |
| 9 | Normal Mast with triple Cantilever Assembly at Viaduct | |
| 10 | Portal with Drop Arm and Single Cantilever Assembly at Viaduct | |
| 11 | Portal with Drop Arm and Double Cantilever Assembly at Viaduct | |
| 12 | Two Track Cantilever Assembly (TTC 5.50/8.0) at Viaduct | |
| 13 | Normal Mast with Single Cantilever Assembly at Grade | |
| 14 | Normal Mast with Multiple Cantilever Assembly at Grade | |
| 15 | Normal Mast with triple Cantilever Assembly at Grade | |
| 16 | Portal with Drop Arm and Single Cantilever Assembly at Grade | |
| 17 | Portal with Drop Arm and Double Cantilever Assembly at Grade | |
| 18 | Two Track Cantilever Assembly (TTC 5.50/8.0) at Grade | |
| 19 | Drop arm support with single cantilever (6"x6" DA) | |
| 20 | Drop arm support with Double cantilever (8"x6" DA) | |
| 21 | Drop arm support with triple cantilever (8"x6" DA) | |
| 22 | Anchoring stay with Fixed Termination-conv. | |
| 23 | Anchoring Stay with Spring Termination Anchor | |
| 24 | Versine | |
| 25 | Anticreep Anchor | |
| 26 | Anticreep Center | ACC |
| 27 | Tension Length | TL |
| 28 | Upright Details (Clearspan) | BFBU/GU(CS:xx) |
| 29 | Sub-Sectioning and Paralleling Post (SSP) | |
| 30 | Sub-Sectioning Post (SS) | |
| 31 | Sectioning and Paralleling Post (SP) | |
| 32 | Feeding Post (FP) | |
| 33 | Obligatory | OBL |
| 34 | To Be Decided | TBD |
| 35 | Interrupter(BM) | |
| 36 | Potential Transformer (PT) | |
| 37 | Lightning Arrestor (LA) | |
| 38 | Booster Transformer | |
| 39 | Spare | |
| 40 | Overhead Protection Conductor Anchor | OPCA |
| 41 | Return Conductor Anchor | RCA |
| 42 | Tramway OHE | |
| 43 | In-Run Wire | |
| 44 | Out-of Run Wire | |
| 45 | PTFE | |
| 46 | Overhead Protection Conductor | |
| 47 | Return Conductor | |
| 48 | Cross feeder | |
| 49 | Slack feeder | |
| 50 | Full Feeding Jumper | |
| 51 | Potential Equalising Jumper | |
| 52 | In-Span Jumper | |
| 53 | RC and OPC Support | |
| 54 | Track at Lower level (Corridor 2) | |
| 55 | Track at UP/DN line (Corridor 2) | |
| 56 | Track at UP & DN (Corridor 1) | |

NOTES:-

1. ALL DIMENSIONS ARE IN METERS UNLESS NOTED OTHERWISE.
2. ALL DIMENSIONS ARE TO BE READ AND NOT TO BE MEASURED.
3. ALIGNMENT OF THE PEGGING PLAN HAS BEEN PREPARED ACCORDING TO THE ALIGNMENT DRAWING RECEIVED FROM GC / KRIDE DT. 08-07-2024.
4. OHE CHAINAGES OF PEGGING PLAN FOR AT GRADE SECTION HAS BEEN REFERRED WITH RESPECT TO DOWN LINE CHAINAGE.
5. SPANS ARE ROUNDED OFF TO NEAREST SINGLE DECIMAL.
6. MAST TYPE SHALL BE DEMARCATED IN PEGGING PLAN AFTER FINALIZATION OF OHE LOAD CALCULATIONS.
7. OHE HEIGHT CLEARANCE UNDER/OVER LINE STRUCTURE (HT. LINE X-ING ETC.) TO BE CONFIRMED OR SPECIAL CARE TO BE TAKEN BEFORE ERECTION FOR THAT PARTICULAR AREA WHEREVER REQUIRED.

FOR TENDER PURPOSE ONLY

NOTES:
1. ALL DIMENSIONS ARE IN METER UNLESS MENTIONED OTHERWISE.
2. ALL DIMENSIONS ARE TO BE READ AND NOT TO BE MEASURED.
3. ANY DISCREPANCY IN THE DRAWING MUST BE BROUGHT TO THE NOTICE OF THE DESIGNER.
4. INTERFACE WITH OTHER DESIGN DISCIPLINE WILL BE DONE AS PER AVAILABILITY OF DETAILS.

| REV | DATE | DESCRIPTION | Originator | Checked | Approved |
|---|---|---|---|---|---|
| R0 | 09-08-2024 | First Submission | IA / SB | CK/NP | RK/SK |

**K RIDE**

DM / ELE / KRIDE | Sr. DGM / ELE / KRIDE | AGM / ELE / KRIDE

Certified that this document has been designed and checked in accordance with GC Quality Assurance Plan.

EGIS-AECOM-WSP

Senior Discipline Expert | Chief Discipline Expert | Project Director

Certified that this document has been designed and checked in accordance with DDC Quality Assurance Plan.

Detailed Design Consultant for design of Traction & Auxiliary Power Supply and Distribution for BSRP

SYSTRA

SYSTRA MVA CONSULTING (INDIA) PVT. LTD.
10th and 11th Floor, Tower-B, 12/3, Vatika
Mindscapes, Mathura Road, NH2, Sector 27D,
Faridabad, Haryana 121013

| Drawn | Checked: | Approved: |
|---|---|---|
| I. Alam | D. Kalyan | R. Kapoor |
| S. Bhati | N. Parmar | S. Kumar |

Client:

RAIL INFRASTRUCTURE DEVELOPMENT COMPANY (KARNATAKA) LIMITED

Project Title: Bengaluru Suburban Rail Project (BSRP)
(Detailed Design Consultant for design of Traction & Auxiliary Power Supply and Distribution for BSRP)

Corridor-2 (Benniganahalli -Soladevanahalli)

Drawing Title: OHE Pegging Plan for Main Line CH: 4+272.500Km to CH:7+015.500Km

Project Stage: Tender Derawing

Paper Size: 5000x297
Discipline: Power Supply & Traction System
Date: 16/08/2024
Scale: NTS

Drawing no.: KRDD001-TDR-CR02-GEN-OCS-PGP-00003
Revision: R0