HEBBAL SUBURBAN
MATHIKERE SUBURBAN
UIOL FOR DN LINE
UIOL FOR UP LINE
DN LINE
UP LINE
C.No.25
C.No.26
C.No.27
C No 28
C.No.28A
C.No.28B
C.No.28C
C.No.28D
C.No.29
BSRP DOWN TRACK
BSRP UP TRACK
ACC CENTRE FOR DN MAIN
ACC CENTRE FOR UP MAIN
PRO. FUTURE STATION (SUBURBAN ELEVATED PF'S & STATION) AT CH: 13455
TENTATIVE LOCATION OF DA SHOWN, OHE TO BE SUPPORTED FROM TRUSSES AND DISTANCE OF TRUSSES REQUIRED FROM STATION BUILDING CONTRACTOR.
EXG.HEBBAL CROSSING STATION KM: 217.185 (WTT) TO BE DISMANTLED
LC No.152
5 M RCC BOX
Refer Drawing No.: KRDD01-TDR-CR02-GEN-OCS-PGP-00007


BENNIGANAHALLI
SOLADEVANAHALLI
HEBBAL SUBURBAN
MATHIKERE SUBURBAN
DN LINE
UP LINE
KM12
ACC DN MAIN

LEGEND

Sr. No.	DESCRIPTION	SYMBOL
1	OHE Span length in metres	(30)
2	Insulated Overlap (IOL)	✕
3	Un insulated Overlap (UIOL)	✕
4	Section Insulator	─◇─
5	Single Pole Isolator	
6	Double pole Isolator with Earth Heel	
7	Normal Mast with Single Cantilever Assembly at Viaduct	■─
8	Normal Mast with Multiple Cantilever Assembly at Viaduct	
9	Normal Mast with triple Cantilever Assembly at Viaduct	
10	Portal with Drop Arm and Single Cantilever Assembly at Viaduct	
11	Portal with Drop Arm and Double Cantilever Assembly at Viaduct	
12	Two Track Cantilever Assembly (TTC 5.50/8.0) at Viaduct	
13	Normal Mast with Single Cantilever Assembly at Grade	●─
14	Normal Mast with Multiple Cantilever Assembly at Grade	
15	Normal Mast with triple Cantilever Assembly at Grade	
16	Portal with Drop Arm and Single Cantilever Assembly at Grade	
17	Portal with Drop Arm and Double Cantilever Assembly at Grade	
18	Two Track Cantilever Assembly (TTC 5.50/8.0) at Grade	
19	Drop arm support with single cantilever (6"x6" DA)	
20	Drop arm support with Double cantilever (8"x6" DA)	
21	Drop arm support with triple cantilever (8"x6" DA)	
22	Anchoring stay with Fixed Termination-conv.	FTA
23	Anchoring Stay with Spring Termination Anchor	BWA
24	Versine	300
25	Anticreep Anchor	ACA
26	Anticreep Center	ACC
27	Tension Length	TL
28	Upright Details (Clearspan)	BFBU/GU(CS:xx)
29	Sub-Sectioning and Paralleling Post (SSP)	
30	Sub-Sectioning Post (SS)	
31	Sectioning and Paralleling Post (SP)	☒
32	Feeding Post (FP)	
33	Obligatory	OBL
34	To Be Decided	TBD
35	Interrupter(BM)	
36	Potential Transformer (PT)	
37	Lightning Arrestor (LA)	
38	Booster Transformer	
39	Spare	■
40	Overhead Protection Conductor Anchor	OPCA
41	Return Conductor Anchor	RCA
42	Tramway OHE	
43	In-Run Wire	──
44	Out-of Run Wire	- - -
45	PTFE	
46	Overhead Protection Conductor	OPC
47	Return Conductor	RC
48	Full Feeding Jumper	
49	Potential Equalising Jumper	
50	In-Span Jumper	
51	RC and OPC Support	▲
52	Track at Lower level (Corridor 2)	— - —
53	Track at UP/DN line (Corridor 2)	──
54	Track at UP & DN (Corridor 1)	──

NOTES:-

1. ALL DIMENSIONS ARE IN METERS UNLESS NOTED OTHERWISE.
2. ALL DIMENSIONS ARE TO BE READ AND NOT TO BE MEASURED.
3. ALIGNMENT OF THE PEGGING PLAN HAS BEEN PREPARED ACCORDING TO THE ALIGNMENT DRAWING RECEIVED FROM GC / KRIDE DT. 08-07-2024.
4. OHE CHAINAGE OF PEGGING PLAN HAS BEEN REFERRED ACCORDING THE ELEVATED GAD RECEIVED FROM L&T ON 10-07-2024:
   - FOR UP & DN (P-1 TO P-77) REFER TO "DRG NO. O22077-BSRP-CR2-C-VD-GEN-10-2001-2004."
   - FOR UP & DN (P-77 TO P-96) REFER TO "DRG NO.O22077-BSRP-CR2-C-VD-GEN-10-2007."
5. CHAINAGES OF OHE LOCATION HAS BEEN CONSIDERED WITH RESPECT TO PIER CENTER LINE DESIGN CHAINAGE FOR BOTH UP & DN LINE .
6. SPANS ARE ROUNDED OFF TO NEAREST SINGLE DECIMAL.
7. MAST TYPE SHALL BE DEMARCATED IN PEGGING PLAN AFTER FINALIZATION OF OHE LOAD CALCULATIONS.
8. OHE HEIGHT CLEARANCE UNDER/OVER LINE STRUCTURE (HT. LINE X-ING ETC.) TO BE CONFIRMED OR SPECIAL CARE TO BE TAKEN BEFORE ERECTION FOR THAT PARTICULAR AREA WHEREVER REQUIRED.

NOTES:

1. ALL DIMENSIONS ARE IN METER UNLESS MENTIONED OTHERWISE.
2. ALL DIMENSIONS ARE TO BE READ AND NOT TO BE MEASURED.
3. ANY DISCREPANCY IN THE DRAWING MUST BE BROUGHT TO THE NOTICE OF THE DESIGNER.
4. INTERFACE WITH OTHER DESIGN DISCIPLINE WILL BE DONE AS PER AVAILABILITY OF DETAILS.

REV	DATE	DESCRIPTION	Originator	Checked	Approved
R0	14-08-2024	FIRST SUBMISSION	KB / SB	CK/NP	RK/SK

K RIDE

DM / ELE / KRIDE
Sr. DGM / ELE / KRIDE
AGM / ELE / KRIDE

Certified that this document has been designed and checked in accordance with GC Quality Assurance Plan.

EGIS-AECOM-WSP

Senior Discipline Expert
Chief Discipline Expert
Project Director

Certified that this document has been designed and checked in accordance with DDC Quality Assurance Plan.

Detailed Design Consultant for design of Traction & Auxiliary Power Supply and Distribution for BSRP

SYSTRA
SYSTRA MVA CONSULTING (INDIA) PVT. LTD.
10th and 11th Floor, Tower-B, 12/3, Vatika Mindscapes, Mathura Road, NH2, Sector 27D, Faridabad, Haryana 121003

Drawn	Checked:	Approved:
K.Bisht	D. Kalyan	R. Kapoor
S. Bhati	N. Parmar	S. Kumar

FOR TENDER PURPOSE ONLY

Client:
RAIL INFRASTRUCTURE DEVELOPMENT COMPANY (KARNATAKA) LIMITED

Project Title: Bengaluru Suburban Rail Project (BSRP)
(Detailed Design Consultant for design of Traction & Auxiliary Power Supply and Distribution for BSRP)
Corridor-2 (Benniganahalli -Soladevanahalli)

Drawing Title:
OHE Pegging Plan for Main Line
CH: 011+200.000Km to
CH:014+062.903(P96)

Project Stage:
Tender Drawing

Paper Size: A3
Discipline: Power Supply & Traction System
Date: 14/08/2024
Scale: NTS

Drawing no.: KRDD01-TDR-CR02-GEN-OCS-PGP-00006
Revision: R0